INDOOR HOME MAINTENANCE CHECKLISTS

WALLS & CEILINGS	DOORS
Clean and in good repair-no holes, water damage, or chipping, flaking, or peeling paint	Interior doors operational and in good condition
No loose wall paper	
RITCHEN	BATHROOMS
Hot(120 degrees)and cold running water	Faucets min 1" gap above spill line
Kitchen sink connected to sanitary sewer, with functioning obstruction-free drains	Openable window or mechanical ventilation required
Cabinets in good repair	Hot and cold running water required from each fixture, fixtures must not leak
	At least 1 lighting fixture
SLEEPING ROOMS	FLOORS
Proper doors/egress window to outside, with clear pathways, windows not blocked	Clean and in good repair- no holes or trip hazards
Operable smoke alarms, light, ventilation, egress windows, and window treatments required	Structurally sound
Window coverings in good repair	
Light fixture or outlets available	
	_
WINDOWS	
WINDOWS Good condition, no broken or cracked glass	
WINDOWS Good condition, no broken or cracked glass Easily openable, screens provided and in good repair	OTHER
WINDOWS Good condition, no broken or cracked glass Easily openable, screens provided and in good repair Locks required	OTHER
WINDOWS Good condition, no broken or cracked glass Easily openable, screens provided and in good repair Locks required Frames in good repair, no chipping or peeling paint	OTHER
WINDOWS Good condition, no broken or cracked glass Easily openable, screens provided and in good repair Locks required Frames in good repair, no chipping or peeling paint	OTHER
WINDOWS Good condition, no broken or cracked glass Easily openable, screens provided and in good repair Locks required Frames in good repair, no chipping or peeling paint	OTHER